



ELECTRICAL TESTING LABORATORY

Nexans Network Solutions N.V. – Div. EUROMOLD
ZUID III, Industrielaan 12
B-9320 EREMBODEGEM (AALST) (Site 2)

TEST CERTIFICATE



The test results of the performed test series are given in the test report
No. TE 213 12 10 from ELAB

Requestor:	Nexans Network Solutions N.V. – Div. Euromold Zuid III – Industrielaan 12 B – 9320 erembodegem (Aalst)
TEST OBJECT	: Combination of separable tee connector and coupling connector for bushings with interface C
TYPE	: P489TB/G-37-400.630-14-5 & P809PB/G-37-400.630-14-5
Rated voltage U_0/U	: 20,8/36 kV
Highest system voltage U_m	: 42 kV
Rated current	: 1250 A
Manufacturer	: NNS N.V. – Div. Euromold
Cable reference	: 1x500 mm ² - Cu – 19/33 kV (code intern: 1x500Cu33-40564) Electric cable 33000V BS 7870 4,10 Nexans -298- 1x500 CU-11-2006
Request number	: TRF 2012-032

Start and end date	Test specification
11/07/2012 – 27/09/2012	HD 629.1 S2 (02/2006) + A1 (09/2008): Test requirements EN IEC 61442 Ed. 2 (03/2005): Test methods
	Test series: Table 7 Test sequence D1

TEST RESULT: the test object successfully passed the prescribed test series.

ELAB

Lab Technician Approval  D. Pennewaert	Techn. Manager – Lab Manager Approval  ing. E. De Ridder
--	---

Erembodegem, 06 November 2012