

## Product Certification Schedule

Schedule No: 174/001/003

Licensee: NEXANS SCHWEIZ AG, PASSWANGSTRASSE 20, CH-4226  
BREITENBACH, SWITZERLAND

Factory: NEXANS SCHWEIZ AG, PASSWANGSTRASSE 20, CH-4226  
BREITENBACH, SWITZERLAND

Specification: BS 5839-1:2002 & A2:2008:2002 - Fire detection and fire alarm systems for buildings - Part 1 Code of practice for system design, installation, commissioning and maintenance. Utilizing BS 7629-1:2008.

Type of Cable: Standard fire resistant cable requirements of BS 5839-1:2002 & A2:2008 26.2(d) utilising BS 7629-1:2008, tested to BS EN 50200:2006 (PH 30 classification) and to Annex E of BS EN 50200:2006. Additionally tested to BS EN 50200:2006 (PH120 classification).

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. 2-core to 19-core inclusive. Sheath - LTS3. Insulation - EI2.

Origin Thread: Not applicable

Origin Mark: NEXANS-CH

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 13/01/2014

Signed for and on behalf of the British Approvals Service for Cables

Date 15/07/2011

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004