

## Product Certification Schedule

Schedule No: 054/001/089  
Licensee: NEXANS SWEDEN AB, SE-514 81, GRIMSAS, SWEDEN  
Factory: NEXANS SWEDEN AB, SE-514 81, GRIMSAS, SWEDEN  
Specification: BS 6724:1997 & A3:2008 - 600/1000V and 1900/3300V armoured electric cables having thermosetting insulation and low emission of smoke and corrosive gases when affected by fire  
Type of Cable: Table 18 - 600/1000V armoured auxiliary cables with stranded copper conductors  
HAR Document: Not applicable  
HAR Specification: Not applicable  
Range of Approval: 1.5sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. 7-core to 48-core inclusive. Sheath - LTS1. Insulation - GP8.  
Origin Thread: Not applicable  
Origin Mark: NEXANS GS



### PERMISSIBLE MARKS

# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 24/10/2013

Signed for and on behalf of the British Approvals Service for Cables

Date 08/08/2011

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004