

BASEC

BRITISH APPROVALS SERVICE FOR CABLES

Product Certification Schedule

Schedule No: 081/001/133
Licensee: NEXANS TURKIYE ENDUSTRI VE TICARET A.S., IZMIR KARAYOLU UZERI
6.KM, DENIZLI, TURKEY
Factory: NEXANS TURKIYE ENDUSTRI VE TICARET A.S., IZMIR KARAYOLU UZERI
6.KM, DENIZLI, TURKEY
Specification: BS 7211:1998 Incorporating Amendment Nos. 1 & 2 - Thermosetting insulated
cables (non-armoured) for electric power and lighting with low emission of
smoke and corrosive gases when affected by fire.
Type of Cable: Table 3a - Thermosetting insulated, non-sheathed cable, 450/750V, single-
core (Rigid copper conductor)
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 1.5sqmm to 300sqmm nominal cross-sectional area of conductors inclusive.
Single-core. Insulation - E15.
Origin Thread: Not applicable
Origin Mark: NEXANS i or NEXANS i)

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 27/10/2013

Signed for and on behalf of the British Approvals Service for Cables

Date 29/11/2011

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004