

Product Certification Schedule

Schedule No: 081/001/143
Licensee: NEXANS TURKIYE ENDUSTRI VE TICARET A.S., IZMIR KARAYOLU UZERI
6.KM, DENIZLI, TURKEY
Factory: NEXANS TURKIYE ENDUSTRI VE TICARET A.S., IZMIR KARAYOLU UZERI
6.KM, DENIZLI, TURKEY
Specification: BS 6004:2000 Incorporating Amendment Nos. 1 & 2 - Electric Cables - PVC
insulated, non-armoured cables for voltages up to and including 450/750 V, for
electric power, lighting and internal wiring.
Type of Cable: Table 4a - PVC insulated, non-sheathed general purpose cable, 450/750 V
single-core (rigid copper conductor).
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 1.5sqmm to 630sqmm nominal cross-sectional area of conductors inclusive.
Single-core. Insulation - T11.
Origin Thread: Not applicable
Origin Mark: NEXANS i or NEXANS i)(or)(126/001

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 27/10/2013

Signed for and on behalf of the British Approvals Service for Cables

Date 29/11/2011

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004