

Product Certification Schedule

Schedule No: 054/001/087
Licensee: NEXANS SWEDEN AB, SE-514 81, GRIMSAS, SWEDEN
Factory: NEXANS SWEDEN AB, SE-514 81, GRIMSAS, SWEDEN
Specification: BS 6724:1997 & A3:2008 - Electric cables - Thermosetting insulated, armoured cables for voltages of 600/1000V and 1900/3300V having low emission of smoke and corrosive gases when affected by fire
Type of Cable: Table 13 - Five-core 600/1000V cables with stranded copper conductors
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 1.5sqmm to 70sqmm nominal cross-sectional area of conductors inclusive. Five-core. Sheath - LTS1. Insulation - GP8.
Origin Thread: Not applicable
Origin Mark: NEXANS GS



PERMISSIBLE MARKS

BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 24/10/2013

Signed for and on behalf of the British Approvals Service for Cables

Date 08/08/2011



This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

004